

PFAS					2022				2023				
					Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	
Regulated Contaminants													
PERFLUORODECANOIC ACID - PFDA	537.1	0.873		ng/L	ND	ND	ND	ND	ND	ND			
PERFLUOROHEPTANOIC ACID-PFHpA	537.1	0.712		ng/L	ND	ND	1.6	1.1	0.82	0.83			
PERFLUOROHEXANESULFONIC ACID-PFHxS	537.1	0.429	Hazard Index	ng/L	ND	ND	0.73	0.49	ND	ND			
PERFLUORONONANOIC ACID-PFNA	537.1	0.728	Hazard Index	ng/L	ND	ND	ND	ND	ND	ND			
PERFLUOROOCETANESULFONIC ACID-PFOS	537.1	0.523	4	ng/L	ND	ND	1.3	0.97	ND	1.7			
PERFLUOROOCETANOIC ACID-PFOA	537.1	0.53	4	ng/L	1.4	1.7	3.5	2	2	2.8			
PFAS6	537.1	0.873	20	ng/L	ND	1.7	3.5	2	2	2.8			
Unregulated Contaminants													
11-CHLOROHEICOSAFLUORO-3-OXAUNDECANE-1-SULFONIC ACID-11CL-PF30UDS	537.1	0.625		ng/L	ND	ND	ND	ND	ND	ND			
4,8-DIOXA-3H-PERFLUORONONANOIC ACID - ADONA	537.1	0.503		ng/L	ND	ND	ND	ND	ND	ND			
9-CHLOROHEXADECANFLUORO-3 OXANONE-1-SULFONIC ACID-9CL-PF3ONS	537.1	0.613		ng/L	ND	ND	ND	ND	ND	ND			
HEXAFLUOROPROPYLENE OXIDE DIMER ACID - HFPO-DA (GENX)	537.1	1.59	Hazard Index	ng/L	ND	ND	ND	ND	ND	ND			
N-ETHYL PERFLUOROOCETANESULFONAMIDOACET IC ACID - NETFOSAA	537.1	0.759		ng/L	ND	ND	ND	ND	ND	ND			
N-METHYL PERFLUOROOCETANESULFONAMIDOACET IC ACID - NMEFOSAA	537.1	0.778		ng/L	ND	ND	ND	ND	ND	ND			
PERFLUOROBUTANESULFONIC ACID-PFBS	537.1	0.508	Hazard Index	ng/L	0.587	0.73	2.1	1.2	1.1	1.2			
PERFLUORODODECANOIC ACID - PFDOA	537.1	1.03		ng/L	ND	ND	ND	ND	ND	ND			
PERFLUOROHEXANOIC ACID - PFHXA	537.1	0.651		ng/L	1.29	1.2	3.8	2.7	1.7	1.6			
PERFLUOROTETRADECANOIC ACID - PFTA	537.1	0.349		ng/L	ND	ND	ND	ND	ND	ND			
PERFLUOROTRIDECANOIC ACID - PFTRDA	537.1	0.37		ng/L	ND	ND	ND	ND	ND	ND			
PERFLUOROUNDECANOIC ACID - PFUNA	537.1	0.381		ng/L	ND	ND	ND	ND	ND	ND			

*Highlighted values in YELLOW indicate the results are J values - Meaning the reported concentration is considered an estimate. A "J" qualifier is used when the measured concentration is lower than the Reporting Limit (RL) but above the minimum detection Limit (MDL). Therefore, not included in PFAS6 totals.

"Regulated Contaminants" are current MADEP regulated PFAS compounds. PFAS6 less than 20ng/L

Compounds in RED are EPA proposed regulated compounds set to be promulgated at the end of 2023. These regulations would supersede current MADEP regulations

Hazard Index - for these four PFAS, water systems would monitor and compare the amount of each PFAS in drinking water to its associated Health- Based Water Concentration (HBWC), which is the level at which no health effects are expected for that PFAS.